

From: [Grace Lewis](#)
To: [Planning Administration](#)
Subject: PP-08479229 - Vastern Court, Caversham Road
Date: 09 November 2021 11:16:37
Attachments: [image002.png](#)

This is an EXTERNAL EMAIL. STOP. THINK before you CLICK links or OPEN attachments.

OFFICIAL



Network Rail
1st Floor
Bristol Temple Point
Bristol
BS1 6NL

My Ref: P/TP21/638
Your Ref: PP-08479229

Date: 9 November 2021

TOWN AND COUNTRY PLANNING ACT 1990 (as amended)

APPLICATION NO: PP-08479229

PROPOSAL: Amended plans- Outline planning permission with the details of access, appearance, landscaping, layout and scale reserved for later determination. A demolition phase and phased redevelopment (each phase being an independent act of development) comprising a flexible mix of the following uses: Residential (Class C3 and including PRS); Offices (Use Class B1(a); development in Use Classes A1, A2, A3 (retail), A4 (public house), A5 (take away), D1 and D2 (community and leisure); car parking; provision of new plant and renewable energy equipment; creation of servicing areas and provision of associated services, including waste, refuse, cycle storage, and lighting; and for the laying out of the buildings; routes and open spaces within the development; and all associated works and operations including but not limited to: demolition; earthworks; provision of attenuation infrastructure; engineering operations.

LOCATION: Vastern Court, Caversham Road

Dear Sir/Madam,

Thank you for your email dated **21 October 2021** together with the opportunity to comment on this proposal.

Network Rail has no objection in principle to the above proposal but due to the proposal being next to Network Rail land and our infrastructure and to ensure that no part of the development adversely impacts the safety, operation and integrity of the operational railway we have included asset protection comments which the applicant is strongly recommended to action should the proposal be granted planning permission.

Any works on this land will need to be undertaken following engagement with Asset Protection

to determine the interface with Network Rail assets, buried or otherwise and by entering into a Basis Asset Protection Agreement, if required, with a minimum of 3months notice before works start. Initially the outside party should contact assetprotectionwestern@networkrail.co.uk.

DRAINAGE

Soakaways / attenuation ponds / septic tanks etc, as a means of storm/surface water disposal must not be constructed near/within 5 metres of Network Rail’s boundary or at any point which could adversely affect the stability of Network Rail’s property/infrastructure. Storm/surface water must not be discharged onto Network Rail’s property or into Network Rail’s culverts or drains. Network Rail’s drainage system(s) are not to be compromised by any work(s). Suitable drainage or other works must be provided and maintained by the Developer to prevent surface water flows or run-off onto Network Rail’s property / infrastructure. Ground levels – if altered, to be such that water flows away from the railway. Drainage is not to show up on Buried service checks.

Yours Sincerely,

Grace Lewis

Town Planning Technician Wales and Western
Network Rail

Temple Point, Redcliffe Way, Bristol, BS1 6NL

E grace.lewis@networkrail.co.uk

www.networkrail.co.uk/property

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.

This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake, please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.

Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office Network Rail, 2nd Floor, One Eversholt Street, London, NW1 2DN.

Click [here](#) to report this email as spam.